



**PROGETTO VALIDO  
PER 45 bar**

THE DRAWING IS PROPERTY OF FRIGOMEC S.p.A. DO NOT REPRODUCE, MODIFY OR DELIVER TO THIRD PARTIES WITHOUT AUTHORIZATION.

SIGNATURE		DESIGNED	CHECKED	APPROVED	MATERIAL	SALT SPRAY TEST CORROSION RESISTANCE 504 HOURS				
DATE: 07/05/2014		Menin	Venturini	Cattivelli	PED-2014/68/UE	PAINTING		LABEL-PLATE CODE	LOGO CE	
DESIGN		DECL. OF CONFORMITY	INSTRUCTION	SCALE		<b>NERO RAL 9005 POLVERE</b>		<b>CEEX-003</b>	<b>CE4.1</b>	
3601/I - SP001		4040404A	A01	-		TYPE <b>RV-200X398</b>				
 SOLUTIONS FOR HVAC&R SYSTEMS		DESCRIPTION			FLUIDS GROUP		<b>2 /</b>	EXCLUDED	<b>/</b>	
					CATEGORY		<b>II /</b>	VOLUME V:L	<b>10 Lt</b>	
					TEMPERATURE TS-°C		<b>-10</b>	<b>120</b>	<b>-50</b>	<b>120</b>
					MAX PERMISSIBLE PRESSURE		<b>45 bar</b>		<b>33 bar</b>	
CODE		WEIGHT	SHEET	TEST PRESSURE		<b>64.35 bar</b>				
<b>1420720A</b>		~6,87 Kg	2 / 2							